

City of Oakley
ADDENDUM NO. 1 to contract documents for

**CIP 218 - MAIN STREET - O'HARA AVENUE INTERSECTION
IMPROVEMENT PROJECT**

BID OPENING DATE: February 27, 2020 2:00 PM

Notice is hereby given that the following clarifications and revisions are made to the above referenced contract documents:

Clarification to the Plans and Specifications:

1. For the bid purpose with regards to soil amendment, follow the ratio indicated in Plan Sheet L0.2, Note 2. Please note that the final soil amendment and fertilization programs shall follow the recommendations from the soil testing laboratory as specified per the Contract Document.
2. See attached sizing chart for lateral lines shown in sheet L4.1.

All bidders shall acknowledge receipt and acceptance of Addendum No. 1 by signing in the space provided at the end of this Addendum and submitting the signed addendum with their proposal.



Jason Kabalin
Capital Projects Coordinator
February 20, 2020

Contractor Signature

Date

Company Name

LATERAL LINE SIZING CHART

SPRINKLER TYPE	GPM	*NO. BUBBLERS	PIPE SIZE
<u>BUBBLERS</u>	1-5 6-10 11-20	1-20 21-40 41-80	3/4" 1" 1 1/4"

* QUANTITY INDICATES NO. OF BUBBLERS, NOT NO. OF TREES.
THERE ARE TWO BUBBLERS PER TREE.