

City of Oakley
ADDENDUM NO. 2 to contract documents for
CIP 255 – Cypress Grove Pump Station Project

BID OPENING DATE: October 6, 2022 2:00 PM

Notice is hereby given that the following clarifications and revisions are made to the above referenced contract documents:

Updates to the Plans and Specifications:

RFI Questions:

1. Can a more clear scope as to what repairs are actually required be provided
2. Can make and model of existing pumps be provided
3. Note 15.06 on drawing A2.1 states rooftop exhaust fan, but not further details are provided. Please provide equipment schedule with details on this fan for quoting purposes.
Note 15.08 on drawing A2.1 states MAXX AIR 36-in Exhaust Fan. The closest match found online for this fan is a MAXX AIR 36" 2-speed belt drive whole house fan with shutter for installation in a residential ceiling. Please provide equipment schedule on this fan for quoting purposes.
Drawing A2.1 notes detail 9/A3.1 at the wall exhaust fans. Detail 9 on A3.1 is for installing a metal louver. Please provide equipment schedule on this louver for quoting purposes.

Corresponding Answers:

1. Pumps shall be serviced to operate in Like-New condition by an OEM certified pump repair and servicing center. All pump components shall be disassembled cleaned, serviced, and tested to return the pumps to back to OEM specifications.

2. The large pumps are Flygt LL3400/715 7900 gpm @ 30' single speed 110hp 460V 3p

The small pump is a Flygt LL3127.090 800 gpm @18' single speed 10hp 460v 3p

3. The following link can be used for bidding purposes

<https://mymaxxair.com/products/36-in-heavy-duty-exhaust-fan-with-automatic-shutter?variant=36669503275165>

All bidders shall acknowledge receipt and acceptance of Addendum No. 2 by signing in the space provided at the end of this Addendum and submitting the signed addendum with their proposal.



Jason Kabalin
Capital Projects Engineer
October 3, 2022

Contractor Signature

Date

Company Name